

NOTE :
- INSTALASI PEMADAM LIHAT JUGA GAMBAR
DIAGRAM SISTEM

KETERANGAN :		
a	b	c
a (HURUF) – NAMA PIPA TEGAK		
b (ANGKA) – NOMOR PIPA TEGAK		
c – NOMINAL DIAMETER		
IHB	= INDOOR HIDRAN BOX	
☐	= PORTABLE FIRE EXTINGUISHER	
PFE	CAP. 5 KG, CO2	
▲	= PORTABLE FIRE EXTINGUISHER	
PFE	CAP. 3 KG, DRY POWDER TYPE	
△	= TROLI FIRE EXTINGUISHER	
TFE	CAP. 25 KG, CO2	
×	= KEPALA SPRINKLER (PENDENT TYPE)	
BCV	= BRANCH CONTROL VALVE	
MCV	= MAIN CONTROL VALVE	
TDV	= TEST DRAIN VALVE	
SP	= PIPA SPRINKLER	
SPDR	= PIPA TEGAK DRAIN SPRINKLER	

PIPE SCHEDULES		
No.	ND (mm)	QUANTITY (PCS)
1	25	2 SPRINKLER
2	32	3 SPRINKLER
3	40	5 SPRINKLER
4	50	10 SPRINKLER
5	65	20 SPRINKLER
6	80	40 SPRINKLER
7	100	100 SPRINKLER

