









CATATAN:

- UPS MENGGUNAKAN SISTEM ONLINE.
- SISTEM KERJA UPS SECARA PARAREL LOAD SHARING, JIKA SALAH SATU UPS GANGGUAN MAKA UPS YANG TIDAK GANGGUAN DAPAT MEMBAKUP BEBAN 100%
- OTONOMI BACKUP PER UPS MINIMUM 15 MENIT.

OWNER/CIENT  APPROVED : .../.../...  ..... (name) ..... (position) (signed) (Dep./Div.)	PROJECT  BPD KELAPA SAWIT  JL.Medan Merdeka Tim, RT.7/RW.1, Gambir, Kec. Gambir, Kota Jakarta Pusat, Daerah Khusus Ibukota Jakarta 10110	INTERIOR DESIGN CONSULTANT  PT.  <b>IDEAS AGKASAMA</b> Jl. Hati Suci No. 4 Gd. Sakura Lt. 2 Room 201 Kel. Kampung Bali, Kec. Tanah Abang, Jakarta Pusat Telp. 021 - 2303483 , Fax. 021 - 2303483 APPROVED : //	MEP CONSULTANT   <b>PT. DUTA PRATAMA ENGINEERING</b> MECHANICAL & ELECTRICAL ENGINEER Rukan Taman Muryo Blok M No. 37, J. Batu Mulia No. 1 Muryo Utara Kembangan – Jakarta Barat 11620 Phone : 021-5845464, 5845547, 5845556, Fax : 021-58474531 Email : djept.me@gmail.com, ptlpe.me@yahoo.com	DRAWING TITLE  DIAGRAM PANEL DP-DATA CENTER  SCALE : NTS  ALL MEASUREMENT MUST BE CHECKED AT BY SITE BY THE CONTRACTORS AND ANY DIFFERENCES REPORTED/INITIATED TO THE DESIGNER FOR CLARIFICATION BEFORE PROCEEDING.		.../.../...	DRAWN Songaji DATE : 15/05/24	DRAWING NUMBER EL-105
						.../.../...	CHECKED Jefri DATE : 15/05/24	PAGE
						.../.../...	DRAWING FOR TENDER	DATE : 2024/05/10
						.../.../...		
						.../.../...		
					#	REVISION :	DATE	