

KETERANGAN :

○	DOWNLIGHT LED OUTBOW-BOX 10 W
⊙	DOWNLIGHT LED OUTBOW-BOX 20 W
EXIT	LAMPU EXIT LED 3 W
+	NICAD BATTERY
◆	DOWNLIGHT LED OUTBOW-BOX 15 W
	+NICAD BATTERY, BACKUP 2 JAM
—	TKO LED 1x20 W
—	TKO LED 2x20 W
EB	+NICAD BATTERY, BACKUP 2 JAM
↵	SAKLAR TUNGGAL
↵	SAKLAR SERI
CL.HL1	HANGING LED STRIP 15W/M REF. BY SPECIAL LIGHTING
CL.LI1	INDIRECT LED STRIP 15W/M REF. BY SPECIAL LIGHTING
W.LI1	WALL LAMP INDIRECT 15W/M REF. BY SPECIAL LIGHTING
FL.LI1	INDIRECT FLOOR LED 15W/M REF. BY SPECIAL LIGHTING
CL.TR1	TRACK LAMP LED 2x5W REF. BY SPECIAL LIGHTING
FL.UP1	FLOOR UPLIGHT 10 W REF. BY SPECIAL LIGHTING
CL.DL1	DOWNLIGHT 20 W REF. BY SPECIAL LIGHTING
CL.HL2	HANGING SPOTLIGHT 15 W REF. BY SPECIAL LIGHTING



APPROVED : .../.../...

..... (name)
..... (position)
..... (Dep./Div.)
(signed)

PROJECT

BPDP
KELAPA SAWIT

Jl. Medan Merdeka Tim, RT.7/RW.1, Gambir,
Kec. Gambir, Kota Jakarta Pusat, Daerah
Khusus Ibukota Jakarta 10110

INTERIOR DESIGN CONSULTANT

PT. MELAKSA
AGKASAMA

Jl. Hati Suci No. 4 Gd. Sakura Lt. 2 Room 201
Kel. Kampung Bali, Kec. Tanah Abang, Jakarta Pusat
Telp. 021 - 2303483 , Fax. 021 - 2303483

APPROVED : //

MEP CONSULTANT



PT. DUTA PRATAMA ENGINEERING

MECHANICAL & ELECTRICAL ENGINEER

Rukan Taman Meruya Blok M No. 37, Jl. Batu Mulia No. 1
Meruya Utara Kembangan - Jakarta Barat 11620
Phone : 021-5845546, 5845547, 5845556, Fax : 021-58474531
Email : dpept.me@gmail.com, pt.dpept@yahoo.com

DRAWING TITLE

DENAH INSTALASI
PENERANGAN
LANTAI 3A

SCALE : 1:150

ALL MEASUREMENT MUST BE CHECKED AT BY SITE
BY THE CONTRACTORS AND ANY DIFFERENCES
REPORTED/INITIATED TO THE DESIGNER FOR
CLARIFICATION BEFORE PROCEEDING.

REVISION

...	.../.../...
...	.../.../...
...	.../.../...
...	.../.../...
...	.../.../...
...	.../.../...
#	REVISION : DATE

DRAWN

Sangaji
DATE : 15/05/24

CHECKED

Jefri
DATE : 15/05/24

DRAWING FOR

DRAWING NUMBER

EL-205

PAGE

TENDER

DATE : 2024/05/10