

NOTE :
- INSTALASI PEMADAM LIHAT JUGA GAMBAR
DIAGRAM SISTEM

KETERANGAN :

a (HURUF) – NAMA PIPA TEGAK
b (ANGKA) – NOMOR PIPA TEGAK
c – NOMINAL DIAMETER


a – b
c

SPR
FH
SPDR
Ø150
Ø80

IHB
PFE
PFE
TIF
BCV
MCV
TDV
SP
SPDR

= INDOOR HIDRAN BOX
= PORTABLE FIRE EXTINGUISHER
CAP. 5 KG, CO2
= PORTABLE FIRE EXTINGUISHER
CAP. 3 KG, DRY POWDER TYPE
= TROLI FIRE EXTINGUISHER
CAP. 25 KG, CO2
= KEPALA SPRINKLER (PENDENT TYPE)
= BRANCH CONTROL VALVE
= MAIN CONTROL VALVE
= TEST DRAIN VALVE
= PIPA SPRINKLER
= PIPA TEGAK DRAIN SPRINKLER

PIPE SCHEDULES		
No.	ND (mm)	QUANTITY (PCS)
1	25	2 SPRINKLER
2	32	3 SPRINKLER
3	40	5 SPRINKLER
4	50	10 SPRINKLER
5	65	20 SPRINKLER
6	80	40 SPRINKLER
7	100	100 SPRINKLER



BDP
KELAPA SAWIT

Jl. Medan Merdeka Tim, RT.7/RW.1, Gambir,
Kec. Gambir, Kota Jakarta Pusat, Daerah
Khusus Ibukota Jakarta 10110

APPROVED : .../.../...

(signature)


..... (name)
..... (position)
..... (Dep./Div.)

INTERIOR DESIGN CONSULTANT

PT. MADEA AGKASAMA

Jl. Heli Sutir No. 4 Gd. Sakura Lt. 2 Room 201
Kel. Kampung Bali, Kec. Tanah Abang, Jakarta Pusat
Telp. 021 - 2303483 , Fax. 021 - 2303483
APPROVED : //

MEP CONSULTANT



PT. DUTA PRATAMA ENGINEERING
MECHANICAL & ELECTRICAL ENGINEER

Revisi: Templat Mengetik Bldg. No. 25, J. Baru Muli No. 1
Kec. Kuning Jaya, Kota Bekasi, Jawa Barat 17132
Phone: 021-2303483, 021-2303483, 021-2303483
Email : dputa-mep@gmail.com, dputa-mep@ptduta.com

DRAWING TITLE

DENAH INSTALASI PEMADAM
KEBAKARAN LANTAI GROUND FLOOR

SCALE : 1 : 150
ALL MEASUREMENT MUST BE CHECKED AT BY SITE
BY THE CONTRACTORS AND ANY DIFFERENCES
REPORTED/INITIATED TO THE DESIGNER FOR
CONFIRMATION BEFORE PROCEEDING.

DRAWN

Maman

DATE : 15/05/24

CHECKED

Sopyan

DATE : 15/05/24

DRAWING FOR

REVISION : R-1

#

DATE

DRAWING NUMBER

PK-201

PAGE

DATE : 2024/05/10

TENDER