








DATA TEKNIS AIR COOLED SPLIT

No.	LOKASI / RUANG YANG DILAYANI	JML. UNIT		KODE UNIT		VOLUME UDARA		KAPASITAS PENDINGIN		EXT. STATIC PRESS. (Inch WG)	TEMP. UDARA		DIAMETER PIPA			DAYA LISTRIK (KW)	KEBUTUHAN HEATER (KW)	DATA LISTRIK (V/Ph/Hz)	TINGKAT KEBISINGAN (dB)	TIPE UNIT	KETERANGAN
		OU	IU	OUTDOOR	INDOOR	FRESH AIR (CFM)	SUPPLY (CFM)	TOTAL (BTU/H)	SENSIBEL (BTU/H)		MASUK (°F DB/WB)	KELUAR (°F DB/WB)	LIQUID (inch)	GAS (inch)	DRAIN (inch)						
01	LANTAI 1																				2 DUTY & 2 UNIT STAND BY
	- DATA CENTER	4	4	OU-1/DC-01~04	IU-01/DC-01~04	--	1.618	55.500	41.625	--	77,5/65,4	54,8/54,2	3/8	5/8	1	6,1	7,5	380/3/50	40	AC PRESISI	
02	LANTAI ATAP																				2 DUTY & 1 UNIT STAND BY
	- RUANG MESIN LIFT	3	3	OU-A/RML-01~03	IU-A/RML-01~03	--	584	20.000	15.000	--	77,5/65,4	54,8/54,2	1/4	1/2	1	1,90	--	220/1/50	40	WALL MOUNTED	

DATA TEKNIS EXHAUST & SUPPLY FAN

NO.	LOKASI / RUANG YANG DILAYANI	KODE UNIT	FUNGSI	JUMLAH UNIT	KAPASITAS	EXT.STATIC	EFFICIENCY MIN (%)	SOUND PRES. LEVEL (dB)	DAYA LISTRIK MOTOR RATING (kW)	PUTARAN MOTOR FAN (RPM)	DATA LISTRIK (V/Ph/Hz)	TIPE FAN	KETERANGAN
					(CFM)	(Inch WG)							
01	LANTAI 1									990 s/d 1450			
	- TOILET, STORAGE	EAF-1/TO.01	EXHAUST	1	500	--	65	55	0,22		220/1/50	AXIAL FAN TYPE	
02	LANTAI 3A												
	- TOILET	CF-3A/TO.01	EXHAUST	1	100	--	65	55	0,04		220/1/50	CEILING FAN	
03	LANTAI ATAP												
	- EXHAUST	EAF-A/.01	EXHAUST	1	6.655	1,00	65	55	2,94		380/3/50	AXIAL FAN TYPE	
	- FRESH AIR	FAF-A/.01	INTAKE	1	5.100	1,00	65	55	2,21		380/3/50	AXIAL FAN TYPE	
	- MAKE UP AIR	SMA-A/.01	MAKE UP AIR	1	4.000	1,50	65	55	1,92		380/3/50	AXIAL SMOKE SPILL	FAN DAPAT BEKERJA PADA SUHU ±250° SELAMA 1 JAM
	- SMOKE EXTRACT	SEF-A/.01	SMOKE EXTRA	1	5.000	1,50	65	55	1,97		380/3/50	AXIAL SMOKE SPILL	FAN DAPAT BEKERJA PADA SUHU ±250° SELAMA 1 JAM

<div>OWNER/CLIENT</div> <div></div> <div>sawit</div> <div>APPROVED : .../.../...</div> <div><div>..... (name)</div><div>..... (position)</div><div>..... (Dep./Div.)</div><div>(signed)</div></div>	<div>PROJECT</div> <div>BPDP KELAPA SAWIT</div> <div>Jl.Medan Merdeka Tim, RT.7/RW.1, Gambir, Kec. Gambir, Kota Jakarta Pusat, Daerah Khusus Ibukota Jakarta 10110</div>	<div>INTERIOR DESIGN CONSULTANT</div> <div>PT. MADEA AGKASAMA</div> <div>Jl. Hati Suci No. 4 Gd. Sakura Lt. 2 Room 201 Kel. Kampung Bali, Kec. Tanah Abang, Jakarta Pusat Telp. 021 - 2303483 , Fax. 021 - 2303483 APPROVED : //</div>	<div>MEP CONSULTANT</div> <div></div> <div>PT. DUTA PRATAMA ENGINEERING MECHANICAL & ELECTRICAL ENGINEER</div> <div>Rukan Taman Murya Blok M No. 37, J. Batu Mulia No. 1 Murya Utara Kemondong - Jakarta Barat 11620 Phone : 021-5845546, 5845547, 5845556, Fax : 021-58474631 Email : dpeptline@gmail.com, pt.dpe.mn@yahoo.com</div>	<div>DRAWING TITLE</div> <div>DATA PERALATAN LEMBAR 2</div> <div>SCALE : NTS</div> <div>ALL MEASUREMENT MUST BE CHECKED AT BY SITE BY THE CONTRACTORS AND ANY DIFFERENCES REPORTED/INITIATED TO THE DESIGNER FOR CLARIFICATION BEFORE PROCEEDING.</div>	<div></div> <div>...</div> <div></div> <div>...</div> <div></div> <div>...</div> <div></div> <div>...</div> <div></div> <div>...</div> <div>#</div> <div>REVISION :</div>	<div>.../.../...</div> <div>.../.../...</div> <div>.../.../...</div> <div>.../.../...</div> <div>.../.../...</div> <div>.../.../...</div> <div>DATE</div>	<div>DRAWN</div> <div>Iqbal</div> <div>DATE : 15/05/24</div>	<div>DRAWING NUMBER</div> <div>VAC-004</div>			
					<div>.../.../...</div> <div>.../.../...</div> <div>.../.../...</div> <div>.../.../...</div> <div>.../.../...</div> <div>.../.../...</div> <div>DATE</div>	<div>CHECKED</div> <div>Dhono</div> <div>DATE : 15/05/24</div>	<div>PAGE</div>				
				<div>DRAWING FOR</div> <div>TENDER</div>							
				<div>DATE : 2024/05/10</div>							